



# Certificate of Compliance

**Certificate:** 80011685

**Master Contract:** 300373

**Project:** 80011685

**Date Issued:** 2019-12-13

**Issued To:** ITT Engineered Valves, LLC  
33 S Centerville Rd  
Lancaster, Pennsylvania, 17603  
United States  
Attention: James R. Daniels

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Vajira Sarathchandra  
Vajira Sarathchandra

## PRODUCTS

CLASS - C337103 - VALVES (GAS) Automatic - For Gas Appliances

CLASS - C337183 - VALVES (GAS) Automatic-For Gas Appliances-Certified to U.S. Standards

Automatic Safety Shut-off Valve Assembly

SKOTCH® Trifecta T4000C Series – 1”, 1½”, 2” - Rated for C/I applications

SKOTCH® Trifecta T4000F Series – 2”, 3”, 4”, 6”

Normally Closed

Ambient Operating temperature: 0°C (-22°F) to 65°C (149°F)

Maximum Operating Pressure: 50 PSIG

Actuation Operating Pressure: 70PSI-120PSI

Operating Electrical Ratings: 110-255VAC, 10A.

## APPLICABLE REQUIREMENTS

ANSI Z21.21-2019•CSA 6.5-2019 Automatic Valves for Gas Appliances with C/I